

From: [lynette.lablack](mailto:lynette.lablack@ipcn.com.au)
To: [Do-Not-Reply IPCN Submissions Mailbox](#); [IPCN Enquiries Mailbox](#)
Subject: IPCN Dubbo Firming Power Station (SSD-28088034)Submission Reference
Date: Friday, 19 April 2024 4:58:35 PM

Dear IPCN,
Please add this Reference to my Submission Objection.
Thank you.

Lynette LaBlack


Paul Miskelly's - Storage requirement for 100 percent Renewables on the Eastern Australian Grid - Initial Findings

Executive Summary - Notes for policymakers

As stated in the Conclusions below:

It would seem that Australian government authorities have not performed and made publicly available any analysis that provides any indication whatsoever, in a readily understandable way, how many “Big Batteries” will be required in Eastern Australia to meet the 100-percent Renewables’ Storage requirement, how they will be sourced and paid for, what are the energy requirements for their production, what are the waste disposal and CO2 emissions resulting therefrom, importantly, where these batteries are to be sited, and, given their relatively short service life, how they will be recycled and re-used.

It beggars belief that none of this absolutely necessary preliminary, investigative work seems to have been addressed by the relevant Australian Planning Authorities.

The findings of this analysis are:

From an analysis based on the AEMO Operational Demand data for calendar year 2023, to even begin to consider a 100-percent Renewables scenario for the Eastern Australian Grid:

1. The present wind and solar energy facilities complement will need to be increased, as a minimum, by a factor of 3.31.
2. The minimum Storage Requirement to provide coverage during the worst extreme, prolonged minima in output of the renewables, must be able to supply the full Demand for a minimum period of 24 days. This translates to a Storage Requirement of 12,077,136 MWh, equivalent to some 27,000 Geelong Big Batteries, or some 94,000 Hornsdale Big Batteries.

According to: <https://victorianbigbattery.com.au/faqs/> , the Geelong battery covers an area of the same size as the Geelong Kardinia Park GMHBA Stadium field. This is an area of some 2 hectares.

Some 27,000 Geelong Big Batteries would occupy an area, a minimum area, of some 54,000 hectares. This does not include the area required for the corridors for the necessary connecting transmission lines. **It is clear that government policy is to acquire rural lands for this purpose, rural lands which are predominantly farmland, that is, land used for food production. This makes it a very significant land grab. This land take is in addition to the considerable amount required for the additional wind and solar**

“farms”, each of which itself constitutes a very significant land grab.

Taking over farmland to build facilities to produce intermittent energy is a violation of Article 2, Section 1(b) of the Paris Agreement (2015).

Article 2 1(b) of the 2015 Paris Agreement states:

“This Agreement... aims to strengthen the global response to the threat of climate change, in the context of sustainable development and efforts to eradicate poverty, including by:
“(b) Increasing the ability to adapt to the adverse impacts of climate change and foster climate resilience and low greenhouse gas emissions development, **in a manner that does not threaten food production**”; See:

https://unfccc.int/files/essential_background/convention/application/pdf/english_paris_agreement.pdf.

Page 1 of 8

Policymakers need to understand, very clearly, that **these storage batteries are merely a band-aid**; they would not be necessary except for very serious shortcomings in the forms of generation that these batteries are required to support.

A battery does NOT extract energy from the wind or the sunshine. These batteries are required simply because both solar and wind generation are highly intermittent forms of generation and these forms of **intermittent generation have a major failing: neither is dispatchable. These forms of generation are also incapable, unlike conventional generation, of providing the very necessary inertia required for grid system security.** The batteries would not be required if these forms of generation were a plug-in replacement for real, conventional generation.

The batteries then are a necessary band-aid. That they are required as a band-aid does not justify the requirement for the vast land-grab that will result from their use. The battery unit itself is NOT a “renewable”, or any other form of, generator.

Also, policymakers need to understand, for this renewables plus battery storage scenario to even begin to be a feasible option:

1. that the battery storage cannot simply be added incrementally over a period of time from some low starting value. It must be available as the amount as stated, that is, 12,077,136 MWh minimum, and it must be fully charged at the time of switch-over to 100-percent renewables.

2. that the renewables complement must be at the level as stated, before shutting down any of the remaining dispatchable generation. Attempting to shut down existing dispatchable, fossil-fuelled generation before the above capacity requirements are met, in full, will merely lead to frequent, unpredictable, widespread blackouts.

Policymakers also need to consider the following:

1. Neither the required units of renewable generation nor the battery storage units “grow on trees” or “pop out of thin air”. At present, all such units are fully imported, increasingly from suppliers whose intentions toward Australia are recognised by Australia’s Security Services as being rather less than benign. At any time, these suppliers could impose a trade embargo on the supply of this equipment, instantly posing a profound risk to National Security. See also Wilson (6).

2. Each Geelong-scale Big Battery will occupy the space, involve the land take, as quoted above, of an AFL football stadium, and then some. Where and how are some 27,000 Geelong Big Battery equivalents going to be sited?

3. What considerations have been given to the transmission line requirements to connect so many of these grid-scale batteries to the Eastern Australian Grid?

4. Where are these grid-scale batteries to be manufactured? What amount of CO₂-producing fossil- fuels will be required to mine the ore, extract, refine and manufacture,

the enormous number of battery modules required?

5. Given the massive scale of the battery requirement, and the known probability of risk of fire, the provision and cost thereof of permanent firefighting facilities and staff, similarly on a massive scale, must be factored into the operations of these battery storage units.

Page 2 of 8

Abstract

Francis Menton, in a recent article (1) , discusses a scholarly paper by a certain Balazs Fekete and colleagues (2), and a blog post article by Fekete himself (3), discussing their experiences in getting the paper published. In the paper, Fekete et al concluded, for the fairly large region of the US that they considered, comprising 18 adjoining northeastern States, that a value of storage, equivalent to some 25 percent of the total annual demand for that region, is the minimum requirement. On an average demand basis, this 25 percent is equivalent to some 91.25 days of demand.

Putting that into the Eastern Australian context, 25 percent of annual demand for the year 2023, based firmly on AEMO operational data, is some 20,970 MW (the average annual demand for 2023), times 24 hours/day times 365 days/year times 25 percent, or, 45,924,300 MWh.

To put that number into some sort of real item of equipment, that is the equivalent of 102,054 Geelong Big Batteries. (The Geelong BB has a stated storage capacity of 450 MWh.)

Clearly, these are enormous numbers, implying an enormous and unprecedented infrastructure requirement, the like of which has never been attempted in Australia, if indeed anywhere.

To seek to put the likely requirement into the context of the Eastern Australian grid, I thought to apply the analytical method described by Fekete et al (ibid.) to the Eastern Australian grid, where, instead of having to deduce likely electricity generation performance from regional wind behaviour and solar irradiance characteristics, as Fekete et al (ibid.) were, it seems, required to do, presumably because they did not have access to electricity performance data for their region, I could use directly the publicly-available, actual AEMO-supplied operational data, thus hopefully removing a significant source of uncertainty in the results from the analysis.

The first step was to sub-total, respectively, the hydro, wind farm, and solar farm data, from the AEMO's NEMWEB site at every 5-minute timepoint from the year 2023 Dispatch_SCADA data. I also collected the AEMO's Operational Demand and estimated Rooftop PV data for 2023. Each of these latter datasets is supplied at 30-minute timepoints, so I presumed to interpolate these values to the intermediate 5-minute timepoints. This approach allowed the use of the Fekete et al. methodology at every 5-minute timepoint.

Note: I did not include pumped-hydro in the hydro subtotals. At present, the operators of pumped- hydro plants are not constrained to purchase the pumping component from renewables' sources, so I have presumed that these sources provide what is essentially delayed fossil-fuel generation.

Methodology

Essentially, as I understand it, the Fekete et al (ibid.) methodology is applied in the following way:

- (a) At the first, or earliest, timepoint in the series of interest, sum the renewables' subtotals (MW), subtract the corresponding demand (MW), the result is the deficit/surplus value at that timepoint.
- (b) Convert this deficit/surplus value to MWh, noting that the time period is 5 minutes, and store it as the accumulated deficit/surplus.
- (c) Repeat at the next timepoint, but for this, and successive timepoints, add the

surplus/deficit from each previous timepoint. (Where it is understood that to "add" is an algebraic addition: a deficit carries a minus sign, so, "adding" a deficit value is essentially subtracting it).

(d) Continue in this fashion, recording the deficit/surplus value at each timepoint, and accumulating a total deficit/surplus value across the entire time span of the operational data.

Page 3 of 8

This process, as Menton (1) observes, is very similar to the procedures used in normal financial profit and loss accounting. It is important to mention "deficits" because, at present, given that the renewables capacity on the Eastern Australian grid is still far short of being able to supply the present demand requirement, running this accumulation process with the current values of the renewables' subtotals quickly results in a very large, negative value, that is, a large deficit, and hence a failure to supply sufficient generation to meet demand.

Before attempting the analysis, it is useful to attempt to place limits on the various likely values, where that is possible. For example, what might be the maximum possible value of the Required Storage, presuming the absolute worst-case conditions?

As the lower limit, the Required Storage cannot be less than zero.

Presumably, the absolute maximum value might be that required to meet one year's Demand. (It may safely be presumed that having all forms of generation shut down for more than a year, which is what this value implies, would be deemed to be totally unacceptable.)

This value is readily determined: Average Demand (MW) times 24 hours times 365 days per year, Inserting the value for Average Demand for calendar year 2023 in the equation: 20966.7409399774 MW times 24 times 365 MWh per year, resulting in a value for the upper limit of the maximum Required Storage of: 183,668,651 MWh (per year).

The range for the value of the Required Storage that would meet the variations in the Total Demand during one year, must lie somewhere within the range: [0 - 183,668,651] MWh.

To attempt to study what would be a likely 100 percent renewables configuration, I thought to run a number of different scenarios where, in each, in turn, I multiply the present wind and solar sub-totals by a positive number, starting at two, and then calculate the accumulation for the entire period (all 5-minute time points for 2023). If that multiplier produces a negative value for the running total of the accumulation – signifying a blackout – then increase that multiplier number and repeat the deficit/surplus calculation for the entire period. Repeat as necessary, increasing the multiplier for each scenario attempted until an overall surplus – no negative values in the running accumulation – results. To give some sort of context, the first, the "multiply-by-two" scenario is equivalent, to a first approximation, to doubling the installed wind and solar farm capacity. Unsurprisingly, this scenario also results in a large deficit, but it is not as large as the first case.

Note: in devising this strategy, I chose not to use multipliers on the Hydro and Rooftop PV subtotals for the following reasons:

- i. given community attitudes regarding hydro dams, it is extremely unlikely that there will be a significant increase in hydro capacity in the foreseeable future,
- ii. Rooftop PV capacity is already so large that it is straining grid stability limits in the middle of the day on almost every day, so it is extremely unlikely that even a doubling of capacity, for example, would continue to be actively encouraged by government policy. (Also, the figures provided by the AEMO for rooftop PV performance are an estimate only.)

In an earlier version of this work, I sought to commence the stepwise process with a Storage of zero, hoping to build it up over time to some sort of steady-state by starting with a sufficiently large multiplier of the current renewables' generation portfolio.

It soon became apparent that this methodology failed, in that a very large initial portfolio of renewables-only generation was required, resulting in the situation that, without

reducing the multiplier over time, the amount in storage just kept increasing monotonically.

Page 4 of 8

I thought to look at other possibilities, first doing a search of the hydrology literature on such as: “sizing reservoir storage to match demand”. I found the following, potentially useful, link: “<https://engineeringnotes.com/water-engineering-2/storage-reservoir/how-to-determine-capacity-of-a-storage-reservoir>”

Two methods were described, the second being what is called the “Mass Curve method”. What became clear here was that, in order to determine the required storage, in any run, the initial storage in the reservoir must be such that, on commencing the march through the timesteps during, for example, one calendar year of 5-minute timesteps,

A first step to a “Real” Battery Scenario

As it is of absolute importance to obtain the best estimate of the storage requirement, I thought to give due consideration to the very real losses in using battery storage. As a first step to including these very real losses in any practical battery storage configuration, I thought, from the outset, to consider the case of the “non-ideal” battery. In a recent email citing a paper at: <https://www.windtaskforce.org/profiles/blogs/battery-system-capital-costs-losses-and-aging>, Willem Post cites the following recommendation from Tesla, the manufacturer of the Hornsdale “Big Battery” in South Australia, that to maximise battery life:

“The 40% throughput is close to Tesla’s recommendation of 60% maximum throughput, i.e., not charging above 80% full and not discharging below 20% full, to achieve a 15-y[ear] life, with normal aging”. See also Post (7) for a comprehensive discussion of grid-scale battery losses.

In determining the accumulating storage then, I needed, at the very least, to ensure that at all times that:

the resulting value for the Required Storage was set at 1.25 times the maximum accumulating storage, (thus ensuring that the accumulating storage never exceeded the battery manufacturer’s requirement that 80 percent of the actual storage is never exceeded),

at any time point, the amount of the storage component available to calculating the deficit/surplus was never such that the residual in the battery storage was permitted to fall below the stipulated 20 percent of the current Required Storage capacity.

What became clear from the use of the hydrologist’s methods is that any iterative attempt at predicting the required storage must presume that the chosen storage is at full capacity at the commencement of the iterative procedure.

Also, it seemed sensible to choose an initial value for the multiplier/s such that the average value of the total available renewables-supplied generation, (that is, wind plus solar plus Rooftop PV plus hydro), is equal to, or just slightly greater than, the average demand for the period under consideration, here the calendar year 2023.

Results

In summary, after trialling many iterations using different multiplier values, I found that the multiplier 3.31 is required, with a storage requirement equivalent to 24 days of average demand. This requirement, remembering that the total storage required is 1.25 times the actual storage required to balance the demand, (given that the storage may be filled to no more than 80 percent of capacity), is 12,077,136 MWh. **This then is the storage required to be able to balance demand at all times throughout calendar year 2023.**

Giving some sort of context to what this bare number means -

it corresponds to 26,842 Geelong Big Batteries, or, 93,633 Hornsdale Big Batteries.

Page 5 of 8

It is useful to compare the latter with an estimate by Paul McArdle, which I understand is

some 70,000 -80,000 Hornsdale Big Batteries. But I further understand that Mr McArdle presumed, as a reasonable first approximation to obtaining a ball-park figure, that the batteries are “ideal”: he did not attempt to address such practicalities as, available storage vs the required storage, transmission losses, two-way trip losses, redundancy required based on battery failure frequency, etc.

The inclusion of any of these many other very real sources of energy losses in the round-trip from generation of surplus through to battery storage to subsequent supply to meet the demand at those times when there is a deficit in the renewables’ output merely increases the required battery storage.

There are several, extremely serious, implications resulting from these findings.

1. Impact on CO2 emissions reductions calculations

With a requirement of some 30,000 “Big Batteries”, there is a clear requirement on the authorities that they determine an accurate estimate of the CO2 emissions resulting from the mining, milling, refining, manufacture of the colossal amounts of materials required for the production, transport and site preparation for this huge number of “Big Batteries” required. That the resulting CO2 emissions might occur in countries outside of Australia does not excuse the requirement for the necessary accounting: any resulting CO2 emissions are released into the same atmosphere.

2. Recycling Burden

Any realistic estimate gives a battery lifetime of some 10-15 years at most. How will it be possible to develop efficient, both in materials and energy efficiency, and effective, recycling and re-use regimes to process such horrendous quantities of waste battery materials? Uttering pious words that “a circular economy will be developed” with no thought as to the detail, as NSW Planning, for example, is doing at the present time, is merely a strategy of leaving the resolution of these horrendous problems to future generations. For a realistic estimate as to the extent of the waste disposal issue, see Mills (4).

3. Environmental Impacts

Given that the Geelong “Big Battery” requires a land-take that is at least equivalent to that of one of Victoria’s Australian Rules Football Stadiums, there is an urgent need to address the likely environmental impacts of what is, by any estimation, a huge land-take requirement. Also worth emphasising is that there can be no argument as to land-use of the land-take required for a BESS. These behmoths occupy the entirety of the land on which they are constructed. There is also the land take required for the enormous amount of overburden and waste rock generated by the mining and milling operations required in the winning of the necessary materials required for the batteries. Again, see Mills (4).

4. Fire Risk

At present, various EIS reports for BESS proposals usually emphasise the risk of fire damage TO the proposed BESS facility from bushfires. There seems to be no account taken of the likely damage to the vicinity of any BESS resulting from fires that start within the facility itself. That there is a very real risk of fires starting in these facilities during, say, a fast-charging scenario, seems at present to be almost totally ignored in these proposals. That there is such a very real risk is indicated by the high rate of fires occurring in domestic premises resulting from the presence of

Page 6 of 8

active, in-use batteries of the same Lithium-Ion technology. To think that such a level of risk can be ignored when of the order of 30,000 Geelong Big Batteries is the requirement, is simply fanciful.

5. National Security Concerns

As each of these “Big Battery” installations takes up a huge area, poses a significant fire risk due to the Lithium-ion technology used, and that there will be potentially so many of them, these big batteries constitute a very real National Security risk. It is not inconceivable that a determined aggressor, using something as simple as a concerted drone attack, could set out to destroy these installations, resulting in Eastern Australia a firestorm that would make, for example, the fire-bombing of Dresden during WWII, look like a village bonfire in comparison. That a grid-wide blackout resulting in the total paralysis nationally for some weeks would be the inevitable result of such an attack seems to be an almost incidental consequence. There is also the very real risk that a cyber attack on any potential “back-door”, built in by foreign suppliers, could be used to shut down the batteries instantly, at any time, producing widespread blackouts. Why have governments seemingly given no thought to the likelihood of such a scenario? See, for example, Prins et al (5) for a UK perspective of the likely devastating impacts on National Security that so-called “Net Zero” policies are already causing and increasingly will have in Britain. For the Australian context and perspective, the excellent paper by Wilson (6) is recommended unreservedly. This paper not only discusses the, entirely negative, impacts of the present policies supporting renewables in Australia, it also provides a foundational basis for the meaning of Energy Security.

Conclusions

This initial analysis indicates that something of the order of the equivalent of some 30,000 Geelong “Big Batteries” will be required to even begin to address the storage requirements of a 100-percent Renewables scenario for the Eastern Australian grid at present electricity Demand requirements. This figure of 30,000 does NOT address the round-trip losses necessarily resulting from the generation, storage, and later release of electrical energy from that storage. Accounting for these very real losses would merely increase the required battery storage figure.

This number of “Big Batteries” resulting from this very preliminary stage of my investigation indicates the requirement for some very serious investigative work, as a matter of extreme urgency, by those in authority who are presently forging ahead with the “100-percent Renewables plus Battery Storage” policies.

It is instructive, I think, to quote from the paper of Fekete et al (2), where they summarise the outcome of their extensive literature search on the topic of the need for the requirement for backup and/or storage to support intermittent renewable generation:

“Perhaps the most disturbing statement was “Many studies suggest that large (>50%) **CO2 emission reductions will not be possible without carbon capture and sequestration (CCS)**” (Loftus

;) citing the “Deep Decarbonization Project”

(). If this is a prevailing sentiment among researchers studying the viability of transitioning the energy sector to renewables, one would wish that they were louder and clearer several decades and trillions of dollar investments ago and informed the public that **renewables are not sustainable since they will always require the assistance of fossil fuels.**”

Similarly, as far as I am able to determine, **no relevant Australian government authority has performed and made publicly available any analysis that provides any indication whatsoever, in a**

et al., 2015

Craig et al., 2017

<https://ddpinitiative.org>

Page 7 of 8

readily understandable way, such as how many “Big Batteries” will be required in

Eastern Australia, how they will be sourced and paid for, what are the energy requirements for their production, the waste disposal and CO2 emissions resulting therefrom, where these batteries will be sited, and, given their relatively short service life, how they will be recycled and re-used.

It beggars belief that none of this absolutely necessary preliminary, investigative work seems to have been addressed by the relevant Australian Planning Authorities. Pursuing this grand dream of “Renewable Energy Superpower” for Australia is, to use a term of Mark Mills, “an exercise in magical thinking”. Put simply, it is time that this nonsense ceased.

Paul Miskelly

4 March 2024

e: 

References

1. Menton F 2023 Another Critical Thinker Reaches The Obvious Conclusion: Intermittent Renewables Can't Work On Their Own. Available at: <https://www.manhattancontrarian.com/blog/2023-12-3-another-critical-thinker-reaches-the-obvious-conclusion-intermittent-renewables-cant-work-on-their-own>.
2. Fekete B M, Bacsko M, Zhang J and Chen M 2023 Storage requirements to mitigate intermittent renewable energy sources: analysis for the US Northeast. *Front. Environ. Sci.*, 11, September 2023, 1076830. Available at: <https://www.frontiersin.org/articles/10.3389/fenvs.2023.1076830/full> .
3. Fekete B M 2023 Net-Zero Targets: Sustainable Future or CO2 Obsession Driven Dead-end? Available at: <https://judithcurry.com/2023/11/14/net-zero-targets-sustainable-future-or-co2-obsession-driven-dead-end/> .
4. Mills M 2020 Mines, Minerals, and “Green” Energy: A Reality Check. 9 July 2020. Available at: <https://media4.manhattan-institute.org/sites/default/files/mines-minerals-green-energy-reality-checkMM.pdf> .
5. Prins G, Kalghatgi G, de La Bedoyere 2024 The Music Stops - Net Zero and National Security. Available at: <https://static1.squarespace.com/static/656f411497ae14084ad8d03a/t/65e18dad4b06fa0c5606a719/1709280690938/Prins-Music-Stops.pdf> .
6. Wilson S 2023 Energy Security is National Security – A Framework for Better Energy Outcomes in Australia. Institute of Public Affairs. Available at: <https://ipa.org.au/publications-ipa/research-papers/energy-security-is-national-security-a-framework-for-better-energy-outcomes-in-australia> , as: <https://ipa.org.au/wp-content/uploads/2023/10/IPA-Research-Energy-Security-is-National-Security-A-framework-for-better-energy-outcomes-in-Australia-October-2023-FINAL.pdf> .
7. Post W 2019 The Hornsdale Power Reserve, Largest Battery System in Australia. Available at: <https://www.windtaskforce.org/profiles/blogs/the-hornsdale-power-reserve-largest-battery-system-in-australia> .